Indoor Model	Vitocal 222-A AWOT-M-E 221.A13
Outdoor Model	Vitocal 200-A AWO-M-E 201.A13
Air-to-water heat pump	yes
Water-to-water heat pump	no
Brine-to-water heat pump	no
Low-temperature heat pump	no
Equipped with a supplementary heater	yes
Heat pump combination heater	ves



Application	Low temperature
Climate conditions	Average

Rated heat output	Prated	10	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj			
T <sub>j</sub> = -7 °C	Pdh	8.8	kW
T <sub>j</sub> = + 2 °C	Pdh	5.7	kW
T <sub>j</sub> = + 7 °C	Pdh	8.9	kW
T <sub>i</sub> = + 12 °C	Pdh	6.6	kW
T <sub>i</sub> = bivalent temperature	Pdh	8.8	kW
T <sub>i</sub> = operation limit temperature	Pdh	8.1	kW
T <sub>i</sub> = - 15 °C (if TOL < -20 °C)	Pdh		kW
Bivalent temperature	T biv	-7	°C
Cycling interval capacity for heating	Pcych		kW
Degradation coefficient	Cdh	0.98	
Power consumption in modes other than active mode			
Off mode	P <sub>OFF</sub>	0.031	kW
Thermostat-off mode	P <sub>TO</sub>	0.000	kW
Standby mode	PSB	0.025	kW
Crankcase heater mode	PCK	0.000	kW
Other items			
Capacity control		variable	
Sound power level, indoors/outdoors	L <sub>WA</sub>	39/56	dB
Annual energy consumption	$Q_{HE}$	4607	kWh
For heat pump combination heater			
		1	1

Seasonal space heating energy efficiency	$\eta_{\text{s}}$	175	%
Declared coefficient of performance for part load at indoor temperature 20 °C and outdoor temperature Tj		•	
T <sub>j</sub> = -7 °C T <sub>j</sub> = +2 °C T <sub>j</sub> = +7 °C T <sub>j</sub> = +12 °C T <sub>j</sub> = +12 °C T <sub>j</sub> = bivalent temperature T <sub>j</sub> = operation limit temperature T <sub>j</sub> = -15 °C (if TOL < -20 °C) Operation limit temperature Cycling interval efficiency Heating water operating limit temperature	COP <sub>d</sub> TOL COPcyc	3.2 4.3 5.6 7.6 3.2 2.9	ဗ
Supplementary heater Rated heat output  Type of energy input	Psup	9.0 Electric	kW
Rated air flow rate, outdoors		4500	m³/h
	· ·		

%

kWh

kWh °C I

 $\eta_{\text{wh}}$ 

Q fuel

AFC

Water heating energy efficiency

Annual fuel consumption Reference hot water temperature DHW volume accounted for in test

Daily fuel consumption

Application	Medium temperature
Climate conditions	Average

Q ele

AEC

4.234

kWh

kWh

Wh/day

Declared load profile

Daily electric consumption Annual electricity consumption Standby cylinder heat loss

Rated heat output	Prated	10	kW
Declared capacity for heating for part load at indoor			
temperature 20 °C and outdoor temperature Tj			
T <sub>i</sub> = - 7 °C	Pdh	8.9	kW
T <sub>i</sub> = + 2 °C	Pdh	5.9	kW
T <sub>j</sub> = + 7 °C	Pdh	5.4	kW
T <sub>j</sub> = + 12 °C	Pdh	6.4	kW
T <sub>j</sub> = bivalent temperature	Pdh	8.9	kW
T <sub>j</sub> = operation limit temperature	Pdh	8.6	kW
T <sub>j</sub> = - 15 °C (if TOL < -20 °C)	Pdh		kW
Bivalent temperature	$T_{biv}$	-7	°C
Cycling interval capacity for heating	Pcych		kW
Degradation coefficient	Cdh	0.98	
Power consumption in modes other than active mode			
Off mode	P <sub>OFF</sub>	0.031	kW
Thermostat-off mode	P <sub>TO</sub>	0.000	kW
Standby mode	P <sub>SB</sub>	0.025	kW
Crankcase heater mode	P <sub>CK</sub>	0.000	kW
Other items			
Capacity control		variable	
Sound power level, indoors/outdoors	L WA	39/56	dB
Annual energy consumption	$Q_{HE}$	6161	kWh

Seasonal space heating energy efficiency	$\eta_{\text{s}}$	130	%
Declared coefficient of performance for part load at indoor temperature 20 °C and outdoor temperature Tj			
$\begin{split} T_j &= -7 \text{ °C} \\ T_j &= +2 \text{ °C} \\ T_j &= +7 \text{ °C} \\ T_j &= +12 \text{ °C} \\ T_j &= \text{ bivalent temperature} \\ T_j &= \text{ operation limit temperature} \\ T_j &= -15 \text{ °C (if TOL < -20 °C)} \\ Operation limit temperature} \\ Cycling interval efficiency \\ Heating water operating limit temperature \\ \end{split}$	COP <sub>d</sub> TOL COPcyc	2.3 3.2 4.2 5.7 2.3 2.0	°C
Supplementary heater Rated heat output Type of energy input	Psup	9.0 Electric	kW
Rated air flow rate, outdoors		4500	m³/h

For heat pump combination heater							
Declared load profile		L		Water heating energy efficiency	$\eta_{wh}$	117	%
Daily electric consumption	Q <sub>elec</sub> 4	.234	kWh	Daily fuel consumption	Q fuel		kWh
Annual electricity consumption	AEC	904	kWh	Annual fuel consumption	AFC		kWh
Standby cylinder heat loss	1	1200	Wh/day	Reference hot water temperature		52.5	°C
				DHW volume accounted for in test		290	1